

Council Study Committee
May 20, 2019
8:30 p.m.
Minutes

Members present: Council members Shirley Clark, Joe Gezel, Bob Kling, Greg Marchant, John Parker and Greta Southall.

Also present were: Ryan Waller, Andy Lent

Jim Rasmussen, HR Green, reported on the following regarding proposed wastewater treatment plant:

- Where HR Green is at with the Design of WWTP
- Potential Construction Schedule
- Defined 30% complete for WWTP
- Major elements still unresolved
- Cost opinion for WWTP has increased significantly
- Cost increases resulting from large increase in materials, volatility in the market, equipment costs and cement costs
- How to avoid additional cost increases
- The new plant will need
 - 13,700 cu yds of concrete
 - 30 miles of wire installed between buildings and equipment
 - 250 – number of contractor's workers needed for the project
 - 0 – number of trucks hauling biosolids for land application
- New plant will meet effluent of:
 - 0.8 mg/l of TP (limit of 1.0 mg/l)
 - 8.0 mg/l of TN (limit of 10.0 mg/l)
 - CBOD of 8.0 mg/l (limit of 25 mg/l)
 - TSS of 8.0 mg/l (limit of 30 mg/l)

Charlie Dissell, Community and Economic Director, presented an update regarding the Missouri Valley JATC Regional Training Facility.

Meeting adjourned at 7:24 p.m.